

No. D 075386 0246 Rev. 00

Holder of Certificate: Shenzhen Kstar New Energy

Company Limited
The 9th Floor, R&D Building

Kstar Industrial Park, Guangming Hi-tech Industrial Zone

518107 Shenzhen, Guangdong Province PEOPLE'S REPUBLIC OF CHINA

Product: Converter

(Hybrid Inverter with storage battery

system)

Model(s): Inverter model: KAC50DP

Battery system model: BC100DE

Parameters: See page 2

Tested CEI 0-16:2022

according to: CEI 0-16:2022/V1:2022 CEI 0-16:2022/V2:2023

CEI 0-16:2022/V3:2024

This Compliance document confirms the compliance with the listed standards on a voluntary basis. It refers only to the sample submitted for testing and certification and does not certify the quality or safety of the serial products. For details see: www.tuvsud.com/ps-cert

Test report no.: 64290243120401

Date, 2024-09-30

(Billy Qiu)



No. D 075386 0246 Rev. 00

Parameters:

Inverter model	KAC50DP		
PV terminal parameters			
Maximum PV voltage [V _{DC}]	1000		
Rated voltage [V _{DC}]	667		
MPPT voltage range [V _{DC}]	350 - 800		
MPPT voltage range (full load) [V _{DC}]	667 - 750		
Maximum input current [A _{DC}]	36/36/36		
Isc PV [A _{DC}]	40/40/40		
MPPT tracker number	3		
Maximum input power [W]	75000		
Battery input/output parameters			
Battery type	LiFePO4		
Maximum voltage [V _{DC}]	750		
Battery rated voltage [V _{DC}]	512		
Battery voltage range [V _{DC}]	350 - 750		
Maximum charge power [W]	55000		
Maximum discharge power [W]	55000		
Maximum charge current [A _{DC}]	55/55		
Maximum discharge current [A _{DC}]	55/55		
Grid terminal input parameters			
Rated input voltage [V _{AC}]	3P+N+PE, 230/400		
Rated input frequency [Hz]	50		
Maximum continuous input current from grid to battery [A _{AC}]	72		
Maximum continuous input current [A _{AC}]	80		
Maximum continuous input power from grid to battery [W]	50000		
Maximum continuous input active power [W]	50000		
Maximum continuous input apparent power [VA]	55000		
Power factor range	0.9 inductive to 0.9 capacitive		
Grid terminal output parameters			
Rated output voltage [V _{AC}]	3P+N+PE, 230/400		
Rated output frequency [Hz]	50		
Rated output current [A _{AC}]	72		
Maximum continuous output current [A _{AC}]	80		
Rated output active power [W]	50000		
Maximum output active power [W]	50000		
Maximum output apparent power [VA]	55000		
Power factor range	0.9 inductive to 0.9 capacitive		
Pattery model parameters and below page: 2			

Battery model parameters see below page: 3





No. D 075386 0246 Rev. 00

The following generators meet the requirements of CEI 0-16:2022, CEI 0-16:2022/V1:2022, CEI 0-16:2022/V2:2023 and CEI 0-16:2022/V3:2024			
Section A	Manufacturer	Shenzhen Kstar New Energy Company Limited The 9th Floor, R&D Building, Kstar Industrial Park, Guangming Hitech Industrial Zone, 518107 Shenzhen, Guangdong Province, PEOPLE'S REPUBLIC OF CHINA	
	Equipment type	Hybrid Inverter with storage battery system	
	Brand	Kstar	
	User side connection	□ Three-phase with neutral □ Three-phase without neutral Frequency: 50 Hz Voltage: 230/400 V _{AC}	
	Primary energy used	☑ Solar ☑ Storage ☐ Wind ☐ Hydroelectric ☐ CHP ☐ Other:	
	Generator model	KAC50DP	
	Rated active power output to Grid	50000 W	
	Maximum apparent power output to Grid	55000 VA	
	The generator:	 ☑ suitable for installation in plants with a power output of less than or equal to 400 kW ☑ suitable for installation in plants with a power exceeding 400 kW 	
	Static converter characteristics		
	Manufacturer of inverter	Shenzhen Kstar New Energy Company Limited	
Section B	Firmware version	V000B000D001	
	Model of inverter	KAC50DP	
	Nominal converter power (P _{NINV})	50000 W	
	Characteristics of the Storage System (SdA)		
Section D	Batteries that can be used with the above static converters		
	Brand	Kstar	
	Technology	LiFePO4	
	Models	BC100DE	
	CUS module (kWh)	102.4 (with 1 × battery system BC100DE, one battery system includes total 20 battery module BC-PACK-5.1-16S-100A (2P10S) in series)	
	BMS firmware version	BAU V3001.31.12.0, BCU V3301.21.12.0, CSU V101.11.0	
	Number of modules	1-2 * BC100DE	
	Note	Batteries are not contained in the inverter and should be installed according to local regulations and in accordance with manufacturer's instruction.	



No. D 075386 0246 Rev. 00

	References of the laboratories that performed the tests and their test reports (RdP)		
Section H	Selected method	☑ Tests performed by an accredited laboratory	
	Test Reports (RdP)	Test report according to Annex Nbis: 64.290.24.31204.01	
	Issued by	Accredited lab: TÜV SÜD Certification and Testing (China) Co., Ltd. Guangzhou Branch	
	Accreditation No.	D-PL-19065-01-00	
	Accreditation body ref.	DAkkS	
Section L	Reference of the certification body		
	Certification Body	TÜV SÜD Product Service GmbH	
		DAkkS accreditation certificate D-ZE-11321-01-00 according to DIN EN ISO/IEC 17065:2013	